

SEWER TREATMENT PLANTS - Environmental Compliance

01 October 2023 -30 September 2024

Mudgee Wastewater Treatment Plant
33 Blain Road, Caerleon, NSW, 2850

Environment Protection Licence: 5230 <http://www.epa.nsw.gov.au/prpoeoapp/>

Monitoring Point 1		pH	EC	TSS	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report generated	Comments	
Pollutant				10	10	0.5		2	10	200			
Limit 90 percentile				30	15	1		10	15	600			
Limit 100 percentile		6.5-8.5											
Units			µs/cm	mg/L	mg/L	mg/L	mg/m3	mg/L	mg/L	CFU/100mL			
Date sampled	Date results received												
11/10/2023	18/10/2023	7.1	1020	5	4.7	0.51	7	<2	2	38	19/10/2023	Higher phosphorus reading detected by Operational staff, Alum dosing adjusted and phosphorus levels back to low levels within a couple of days	
8/11/2023	15/11/2023	7.6	1040	2	4.5	0.11	<1	<2	<2	<1	15/11/2023		
14/12/2023	27/12/2023	7.5	1080	2	6.5	0.16	11	<2	2	10		2/01/2024	
15/01/2024	22/01/2024	7.6	1040	<1	4.9	0.16	1	<2	<2	10		24/01/2024	
14/02/2024	22/02/2024	7.6	976	2	6.9	0.25	6	<2	3	40		23/02/2024	
13/03/2024	20/03/2024	7.5	936	3	5.3	0.14	4	<2	<2	430		21/03/2024	Elevated Faecal coliforms under investigation
No of samples taken		6	6	6	6	6	12	6	6	6			
EPA required frequency (samples per year)		Monthly (12)		Monthly (12)	Monthly (12)	Monthly (12)		Monthly (12)	Monthly (12)	Monthly (12)			
Minimum		7.1	936	0.5	4.5	0.11	1	1.0	1.0	1			
Average		7.5	1015	2.4	5.5	0.22	6	1.0	1.7	88			
Maximum		7.6	1080	5	6.9	0.51	11	1	3	430			
Samples within 90 % limits (%)				100	100	83		100	100	83			
Samples within 100 % limits (%)		100		100	100	100		100	100	100			

SEWER TREATMENT PLANTS - Environmental Compliance		01 October 2023 -30 September 2024						
Mudgee Wastewater Treatment Plant								
33 Blain Road, Caerleon, NSW, 2850								
Environment Protection Licence: 5230								
Monitoring Point 2		Min	Max	Average	No of reading taken	Number of reading required	Comments	
Frequency: daily								
Limits		11500 KL/Day	11500 KL/Day	11500 KL/Day				
Units		KL	KL	KL				
Month	Report generated							
October	6/11/2023	2218	4462	3086	31	31		
November	5/12/2023	2169	5596	2922	30	30		
December	3/01/2023	1860	4398	2947	31	31		
January	5/02/2024	2072	4477	3031	31	31		
February	1/03/2024	2174	5652	3050	29	29		
March	9/04/2024	1983	3603	2812	31	31		
April						30		
May						31		
June						30		
July						31		
August						31		
September						30		

SEWER TREATMENT PLANTS - Environmental Compliance		01 October 2023 -30 September 2024						
Mudgee Wastewater Treatment Plant								
33 Blain Road, Caerleon, NSW, 2850								
Environment Protection Licence: 5230								
Monitoring Point 3		Min	Max	No of days flowing	No of reading	Number of reading required	Comments	
Frequency: daily								
Limits								
Units		KL	KL					
Month	Report generated							
October	6/11/2023	0	0	0	31	31		
November	5/12/2023	0	0	0	30	30		
December	3/01/2023	0	0	0	31	31		
January	5/02/2024	0	0	0	31	31		
February	1/03/2024	0	1	0	29	29		
March	9/04/2024	0	0	0	31	31		
April						30		
May						31		
June						30		
July						31		
August						31		
September						30		