

7/08/2018	14/08/2018					<0.2							
5/09/2018	12/09/2018	8.5	578	387	6	<0.2	1.2	0.08	10	<2	3	140	
10/10/2018	22/10/2018					<0.4							
10/12/2018	18/12/2018					<0.2							
7/01/2019	18/01/2018					<0.2							
6/02/2019	15/02/2019					<0.2							
5/03/2019	14/03/2019					<0.2							
9/04/2019	23/04/2019					<0.2							
No of samples taken		1	1	1	1	11	1	1	1	1	1	1	
Samples/year required by EPA		1			1	12	1	1		1	1	1	
Minimum						0.1							
Average						0.1							
Maximum						0.2							

SEWER TREATMENT PLANTS - Environmental Compliance													01 April 2018 -31 March 2019	
Rylstone Sewage treatment Works Crawell Street, Rylstone 2849 NSW Environment Protection Licence: 1958 http://www.epa.nsw.gov.au/prpoeoapp/													Report generated	
Monitoring Point 5		pH	EC	TDS (calculated)	TSS	Chlorine total	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Comments	
Pollutant			µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/m3	mg/L	mg/L	CFU/100mL		
Units														
Date sampled	Date results received													
5/09/2018	12/09/2018	8.2	579	388	5	<0.2	0.8	0.02	12	<2	<2	5		
No of samples taken		1	1	1	1	1	1	1	1	1	1	1		
Samples/year required by EPA		1			1		1	1		1	1	1		

SEWER TREATMENT PLANTS - Environmental Compliance						01 April 2018 -31 March 2019	
Rylstone Sewage treatment Works Crawell Street, Rylstone 2849 NSW Environment Protection Licence: 1958						Report generated	
Monitoring Point 1	Total	Samples within Limits (%)	No of reading taken	Number of reading required	Comments		
Frequency: daily	100 ML/Year (100000 KL/Year)						
Limits							
Units	KL	KL					
Month							
April	3074	100	30	30			
May	3247	100	31	31			
June	3834	100	30	30			
July	3377	100	31	31			
August	3581	100	31	31			
September	3581	100	30	30			
October	3354	100	31	31			
November	2906	100	30	30			

December	2973	100	31	31	
January	3486	100	31	31	
February	2356	100	28	28	
March	3274	100	31	31	
Yearly TOTAL	39043	100	365	365	